

Building Contagion Mitigation Certificate

Levels	# of Rooms Pre Mitigation	# of Rooms Mitigation	Controls
6	3	3	
5		1	
4		3	
3			
2	2	2	
1	2	2	
0	4		

Building Name: Elementary School**Building Number:** 10**Street:****City:****State:****Zip:****Inspector Name:****Signature Date:** mm/dd/yyyy**Average Cert Level:** 4**Average Cert Level Mitigation:** 5

Control shows the risk level of the ventilation being turned off when the public is present. If it is not running the control level is very low and the contagion risk is very high. Systems with the highest levels are fully automated with alarms. Systems with lowest levels can be turned off by anyone with access including the public.

Summary	Min	Max	Average
Final AUC	0	157	48
Cert Level	0	6	4
Final AUC Mitigation	2	257	76
Cert Level Mitigation	1	6	5

Product Key: 123456

Not valid without product key.

Signature

Date

Room Details - Office Record

0. **mode:** site-survey
1. **Project:** School District
2. **Date:** mm/yy/yyyy
3. **Building Name:** Elementary School
4. **Building Number:** 10
5. **Street:**
6. **City:**
7. **State:**
8. **Zip:**

82. **Notes and Observations:**

83. **Inspector Name:**

84. **Signature Date:** mm/dd/yyyy

Building Rooms:

Levels	# of Rooms Pre Mitigation	# of Rooms Mitigation	Controls
6	3	3	
5		1	
4		3	
3			
2	2	2	
1	2	2	
0	4		

Building Summary:

Summary	Min	Max	Average
Final AUC	0	157	48
Cert Level	0	6	4
Final AUC Mitigation	2	257	76
Cert Level Mitigation	1	6	5

Room Contagion Mitigation Certificate

Levels	Room Level Pre Mitigation	Room Level Mitigation	Controls
6			
5			
4			
3			
2	2	2	
1			
0			

Building Name: Elementary School**Building Number:** 10**Street:****City:****State:****Zip:****Room Number:****Room Name:****Inspector Name:****Signature Date:** mm/dd/yyyy**Cert Level:** 2**Cert Level Mitigation:** 2

Product Key: 123456

Not valid without product key.

Signature

Date

Room Details - Office Record

0. **mode:** site-survey
1. **Project:** School District
2. **Date:** mm/yy/yyyy
3. **Building Name:** Elementary School
4. **Building Number:** 10
5. **Street:**
6. **City:**
7. **State:**
8. **Zip:**
9. **HVAC Zone Name:** one
10. **HVAC Model Number:**
11. **Total Cubic Feet Serviced By This Zone:**
12. **HVAC Fan Size CFM:** 620
13. **Number of Rooms Serviced by this Zone:** 1
14. **List Room Survey Numbers:**
15. **HVAC Zone a-AUC:** 0
16. **HVAC Automated Alarms:** no
17. **Manual Dampers in Ducts:** yes
18. **Thermostat Control by Users:** yes
19. **Thermostat Locks Removed:** yes
20. **Visible Vent Manually Controlled:** yes
21. **System Fans on ALL the time:** no
22. **System Fans on when public is present:** yes
23. **Number:**
24. **Room Name:**
25. **Length:** 30
26. **Width:** 30
27. **Height:** 10
28. **Cubic Feet:** 9000
29. **Number Of Windows:** 0
30. **Windows Fully Open:** no
31. **Windows Not Blocked:** no
32. **Door Open:** no
33. **Door Not Blocked:** yes
34. **w-AUC:** 0
35. **Number of Exhaust Fans:** 0
36. **Intake Vents Fully Open:** yes
37. **Intake Vents Not Blocked:** yes
38. **Total Exhaust Fans CFM:** 0
39. **Total Exhaust Fans fAUC:** 0
40. **Forced Air Heating:** no
41. **Forced Air Heating Cooling:** yes
42. **Forced Air Fan Option:** yes
43. **Exhaust Vents Fully Open:** yes
44. **Number of Exhaust Vents:** 0
45. **Exhaust Vents Not Blocked:** yes
46. **Number of Intake Vents:** 0
47. **HVAC Intake Vents Fully Open:** yes

48. **HVAC Intake Vents Not Blocked:** yes
49. **Visual Streamers:** no
50. **t-AUC:** 0
51. **a-AUC:** 0
52. **Number of UV-C Fixtures:** 0
53. **UV-C Model:**
54. **UV-C Total Watts:** 0
55. **UV-C eAUC:** 0
56. **UV C Public View On/Off Indicators:** no
57. **UV-C Automated Alarms:** no
58. **Number of Far UV Fixtures:** 0
59. **Far-UV Model:**
60. **Far-UV Total Watts:** 0
61. **Far-UV eAUC:** 0
62. **Far UV Public View On/Off Indicators:** no
63. **Far UV Automated Alarms:** no
64. **Number of Air Sanitizers:** 0
65. **Air Sanitizers Model:**
66. **Air Sanitizers Total CFM:** 0
67. **Air Sanitizers sAUC:** 0
68. **Air Sanitizers Public View On/Off Indicators:** no
69. **Air Sanitizers Automated Alarms:** no
70. **Number of PCO/other units:** 0
71. **PCO/other Model:**
72. **Claimed effective ep AUC:** 0
73. **Claimed effective ep AUC Test Authority:**
74. **PCO/other units Total CFM:** 0
75. **PCO/other units Public View On/Off Indicators:** no
76. **PCO/other units Automated Alarms:** no
77. **Occupancy Number:** 0
78. **Room Occupancy Sign Posted:** yes
79. **Public Present During Site Survey:** no
80. **Data Entered Directly Into Computer:** yes
81. **Printout Attached To Paper Form:** no
82. **Notes and Observations:**
83. **Inspector Name:**
84. **Signature Date:** mm/dd/yyyy
85. **Total AUC:** 4.13333333333333
86. **Large Room Factor:** 1
87. **Final AUC:** 4.13333333333333
88. **Cert Level:** 2
89. **Final AUC Mitigation:** 4.13333333333333
90. **Cert Level Mitigation :** 2

Room Contagion Mitigation Certificate

Levels	Room Level Pre Mitigation	Room Level Mitigation	Controls
6			
5			
4		4	
3			
2	2		
1			
0			

Building Name: Elementary School**Building Number:** 10**Street:****City:****State:****Zip:****Room Number:** 2**Room Name:****Inspector Name:****Signature Date:** mm/dd/yyyy**Cert Level:** 2**Cert Level Mitigation:** 4

Product Key: 123456

Not valid without product key.

Signature

Date

Room Details - Office Record

0. **mode:** site-survey
1. **Project:** School District
2. **Date:** mm/yy/yyyy
3. **Building Name:** Elementary School
4. **Building Number:** 10
5. **Street:**
6. **City:**
7. **State:**
8. **Zip:**
9. **HVAC Zone Name:** one
10. **HVAC Model Number:**
11. **Total Cubic Feet Serviced By This Zone:**
12. **HVAC Fan Size CFM:** 620
13. **Number of Rooms Serviced by this Zone:** 1
14. **List Room Survey Numbers:**
15. **HVAC Zone a-AUC:** 0
16. **HVAC Automated Alarms:** no
17. **Manual Dampers in Ducts:** yes
18. **Thermostat Control by Users:** yes
19. **Thermostat Locks Removed:** yes
20. **Visible Vent Manually Controlled:** yes
21. **System Fans on ALL the time:** no
22. **System Fans on when public is present:** yes
23. **Number:** 2
24. **Room Name:**
25. **Length:** 30
26. **Width:** 30
27. **Height:** 10
28. **Cubic Feet:** 9000
29. **Number Of Windows:** 0
30. **Windows Fully Open:** no
31. **Windows Not Blocked:** no
32. **Door Open:** no
33. **Door Not Blocked:** yes
34. **w-AUC:** 0
35. **Number of Exhaust Fans:** 0
36. **Intake Vents Fully Open:** yes
37. **Intake Vents Not Blocked:** yes
38. **Total Exhaust Fans CFM:** 0
39. **Total Exhaust Fans fAUC:** 0
40. **Forced Air Heating:** no
41. **Forced Air Heating Cooling:** yes
42. **Forced Air Fan Option:** yes
43. **Exhaust Vents Fully Open:** yes
44. **Number of Exhaust Vents:** 0
45. **Exhaust Vents Not Blocked:** yes
46. **Number of Intake Vents:** 0
47. **HVAC Intake Vents Fully Open:** yes

48. **HVAC Intake Vents Not Blocked:** yes
49. **Visual Streamers:** no
50. **t-AUC:** 0
51. **a-AUC:** 0
52. **Number of UV-C Fixtures:** 2
53. **UV-C Model:**
54. **UV-C Total Watts:** 50
55. **UV-C eAUC:** 24
56. **UV C Public View On/Off Indicators:** yes
57. **UV-C Automated Alarms:** yes
58. **Number of Far UV Fixtures:** 0
59. **Far-UV Model:**
60. **Far-UV Total Watts:** 0
61. **Far-UV eAUC:** 0
62. **Far UV Public View On/Off Indicators:** no
63. **Far UV Automated Alarms:** no
64. **Number of Air Sanitizers:** 0
65. **Air Sanitizers Model:**
66. **Air Sanitizers Total CFM:** 0
67. **Air Sanitizers sAUC:** 0
68. **Air Sanitizers Public View On/Off Indicators:** no
69. **Air Sanitizers Automated Alarms:** no
70. **Number of PCO/other units:** 0
71. **PCO/other Model:**
72. **Claimed effective ep AUC:** 0
73. **Claimed effective ep AUC Test Authority:**
74. **PCO/other units Total CFM:** 0
75. **PCO/other units Public View On/Off Indicators:** no
76. **PCO/other units Automated Alarms:** no
77. **Occupancy Number:** 0
78. **Room Occupancy Sign Posted:** yes
79. **Public Present During Site Survey:** no
80. **Data Entered Directly Into Computer:** yes
81. **Printout Attached To Paper Form:** no
82. **Notes and Observations:**
83. **Inspector Name:**
84. **Signature Date:** mm/dd/yyyy
85. **Total AUC:** 4.13333333333333
86. **Large Room Factor:** 1
87. **Final AUC:** 4.13333333333333
88. **Cert Level:** 2
89. **Final AUC Mitigation:** 28.1333333333333
90. **Cert Level Mitigation :** 4

Room Contagion Mitigation Certificate

Levels	Room Level Pre Mitigation	Room Level Mitigation	Controls
6	6	6	
5			
4			
3			
2			
1			
0			

Building Name: Elementary School**Building Number:** 10**Street:****City:****State:****Zip:****Room Number:****Room Name:****Inspector Name:****Signature Date:** mm/dd/yyyy**Cert Level:** 6**Cert Level Mitigation:** 6

Product Key: 123456

Not valid without product key.

Signature

Date

Room Details - Office Record

0. **mode:** site-survey
1. **Project:** School District
2. **Date:** mm/yy/yyyy
3. **Building Name:** Elementary School
4. **Building Number:** 10
5. **Street:**
6. **City:**
7. **State:**
8. **Zip:**
9. **HVAC Zone Name:**
10. **HVAC Model Number:**
11. **Total Cubic Feet Serviced By This Zone:**
12. **HVAC Fan Size CFM:**
13. **Number of Rooms Serviced by this Zone:** 1
14. **List Room Survey Numbers:**
15. **HVAC Zone a-AUC:** 0
16. **HVAC Automated Alarms:** no
17. **Manual Dampers in Ducts:** yes
18. **Thermostat Control by Users:** yes
19. **Thermostat Locks Removed:** yes
20. **Visible Vent Manually Controlled:** yes
21. **System Fans on ALL the time:** no
22. **System Fans on when public is present:** yes
23. **Number:**
24. **Room Name:**
25. **Length:** 100
26. **Width:** 100
27. **Height:** 20
28. **Cubic Feet:** 200000
29. **Number Of Windows:** 10
30. **Windows Fully Open:** yes
31. **Windows Not Blocked:** yes
32. **Door Open:** yes
33. **Door Not Blocked:** yes
34. **w-AUC:** 0
35. **Number of Exhaust Fans:** 4
36. **Intake Vents Fully Open:** yes
37. **Intake Vents Not Blocked:** yes
38. **Total Exhaust Fans CFM:** 3600
39. **Total Exhaust Fans fAUC:** 0
40. **Forced Air Heating:** no
41. **Forced Air Heating Cooling:** yes
42. **Forced Air Fan Option:** yes
43. **Exhaust Vents Fully Open:** yes
44. **Number of Exhaust Vents:** 0
45. **Exhaust Vents Not Blocked:** yes
46. **Number of Intake Vents:** 0
47. **HVAC Intake Vents Fully Open:** yes

48. **HVAC Intake Vents Not Blocked:** yes
49. **Visual Streamers:** no
50. **t-AUC:** 0
51. **a-AUC:** 0
52. **Number of UV-C Fixtures:** 0
53. **UV-C Model:**
54. **UV-C Total Watts:** 0
55. **UV-C eAUC:** 24
56. **UV C Public View On/Off Indicators:** yes
57. **UV-C Automated Alarms:** yes
58. **Number of Far UV Fixtures:** 0
59. **Far-UV Model:**
60. **Far-UV Total Watts:** 0
61. **Far-UV eAUC:** 0
62. **Far UV Public View On/Off Indicators:** no
63. **Far UV Automated Alarms:** no
64. **Number of Air Sanitizers:** 0
65. **Air Sanitizers Model:**
66. **Air Sanitizers Total CFM:** 0
67. **Air Sanitizers sAUC:** 0
68. **Air Sanitizers Public View On/Off Indicators:** no
69. **Air Sanitizers Automated Alarms:** no
70. **Number of PCO/other units:** 0
71. **PCO/other Model:**
72. **Claimed effective ep AUC:** 0
73. **Claimed effective ep AUC Test Authority:**
74. **PCO/other units Total CFM:** 0
75. **PCO/other units Public View On/Off Indicators:** no
76. **PCO/other units Automated Alarms:** no
77. **Occupancy Number:** 0
78. **Room Occupancy Sign Posted:** yes
79. **Public Present During Site Survey:** no
80. **Data Entered Directly Into Computer:** yes
81. **Printout Attached To Paper Form:** no
82. **Notes and Observations:**
83. **Inspector Name:**
84. **Signature Date:** mm/dd/yyyy
85. **Total AUC:** 38.08
86. **Large Room Factor:** 4.14
87. **Final AUC:** 157.6512
88. **Cert Level:** 6
89. **Final AUC Mitigation:** 257.0112
90. **Cert Level Mitigation :** 6

[Main Menu](#)